


Pumping Problem

Find the size of pipe that minimizes the total annual capital plus operating cost assuming a 10 year service life and $i=12\%$. Assume the pipe's installed cost per foot is $\$65 + \$100 \cdot (\text{Dia}/\text{in})^{1.5}$ with a salvage value of $\$10 \cdot (\text{Dia}/\text{in})$ per ft. Schedule 40 steel pipe is available in nominal integer inch diameter increments. The pump runs 50% of the time. Energy costs are $\$60/\text{MW}\cdot\text{hr}$



$$GLD := 7 \quad ELD := 15 \quad \Delta z := 29 \cdot m \quad f := 0.004 \quad C := \frac{0.00000006}{W \cdot hr} \text{ k\$/W}\cdot\text{hr}$$

$$W := \pi \cdot 1 \cdot m^2 \cdot 10 \cdot m \cdot 1000 \cdot \frac{kg}{m^3} \cdot \frac{1}{1200 \cdot s}$$

$$j := 1, 2 \dots 500$$

$$d_j := 2 \cdot cm + \frac{j-1}{40} \cdot cm \quad D := d \quad V := \frac{10 \cdot m}{1200 \cdot s} \cdot \left(\frac{2 \cdot m}{D} \right)^2 \quad Mp := (\Delta z \cdot g)$$


$$Me_j := \left(\left(2 \cdot f \cdot \left(\frac{20 \cdot m}{D_j} + GLD + ELD \right) + \frac{1}{2} \cdot 0.5 + \frac{1}{2} \cdot (0.8 + 1) \right) \cdot V_j^2 \right)$$

$$HPp_j := Mp \cdot W \quad HPe := Me \cdot W \quad pctFL := \frac{HPe}{HPe + HPp}$$



$$pctFL_{500} = 2$$

$$AnnualOpCost := (HPp + HPe) \cdot 12 \cdot 365 \cdot hr \cdot C$$

$$\frac{HPp \text{ (hp)}}{HPe \text{ (4 hp)}}$$



$$D \text{ (in)}$$



Engineer Economics determination of minimum Total Cost

$$pct := 12\% \quad n := 12 \quad L := 20 \cdot m$$

$$A_P := \frac{pct \cdot (1 + pct)^n}{(1 + pct)^n - 1} = 0.161 \quad A_F := \frac{pct}{(1 + pct)^n - 1} = 0.041$$

Present Cost

$$CP := \left(\frac{30}{ft} + \frac{70}{ft} \cdot \left(\frac{D}{1 \cdot in} \right)^{1.2} \right) \cdot \frac{L}{1000} \quad SV := \frac{10}{ft} \cdot L \cdot \frac{D}{in} \cdot \frac{1}{1000}$$



Annualized Capital Cost less SV in K\$

$$AC := (CP \cdot A_P - SV \cdot A_F)$$

Total Cost = AC + Annual Operating Cost

$$TC := AC + AnnualOpCost$$

$$MinCost := \min(TC) = 5.738$$



Find i at 3.07" (see table below): solve for i

$$d_j := 2 \cdot cm + \frac{j-1}{40} \cdot cm$$

$$J := \text{round}\left(\frac{((3.07 \cdot in - 2 \cdot cm) \cdot 40 + 1 \cdot cm)}{cm}, 0\right) = 233$$

Use J = 233 at 3" nominal Dia. pipe

$$MinAnnualCost_At_3_in_Dia := TC_J = 5.738$$

The following chart shows the relationship of the various NPS sizes and Schedules and the actual Outside Diameter and Wall Thickness.

NOMINAL PIPE SIZE	OD	SCH 5	SCH 10	SCH 40	SCH 80
1/2"	0.84	0.065	0.083	0.109	0.147
3/4"	1.05	0.065	0.083	0.113	0.154
1"	1.315	0.065	0.109	0.133	0.179
1-1/4"	1.66	0.065	0.109	0.14	0.191
1-1/2"	1.9	0.065	0.109	0.145	0.2
2"	2.375	0.083	0.109	0.154	0.218
2-1/2"	2.875	0.083	0.12	0.203	0.276
3"	3.5	0.083	0.12	0.216	0.3
3-1/2"	4	0.083	0.12	0.226	0.318
4"	4.5	0.083	0.12	0.237	0.337

REF <https://www.atc-mechanical.com>

3" Schedule 40 - ID=3.07"

Optimal Design Cost Summary (K\$)

$$AnnualCapitalCost := AC_J = 3.084 \quad AnnualOpCost_J = 2.654$$

$$pctCostForEnergy := \frac{AnnualOpCost_J}{AC_J + AnnualOpCost_J} = 46.3\%$$

$$pctCostForPiping := \frac{AC_J}{AC_J + AnnualOpCost_J} = 53.7\%$$

$$pctPowerForFrictionalLoss_J := pctFL_J = 26.3\%$$

$$pctPowerUsedForMovingWaterUp := 1 - pctFL_J = 73.7\%$$